



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Easton Rains

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 Winston Salem, NC 27105

**Little Kitchen**  
 3501 Buck Shoals Rd  
 Union Grove,

**EIN:** 566000372X

**Delivery:** NC Courier

**Yadkin County**

StarLiMS ID: <b>ES240711-0049</b>	Date Collected: 07/10/2024	Time Collected: 11:11	By: Easton Rains
	Date Received: 07/11/2024	Time Received: 08:23	By: Julie Schiavone
Water System ID: 02-99-486	System Type: NTNC	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: kitchen sink	Location Type:	Location Code: KS1	
Disinfectant Used:	Free Chlorine:	Total Chlorine: 0.0 mg/L	
Comments: No disinfectant used			

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/11/2024
E. coli	Absent			07/11/2024

**Report Date:** 07/12/2024

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.