



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Mandi Pearson

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Tina Fortney
16 Baker Rd
Arden, NC 28704

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES240711-0083**

Date Collected: 07/10/2024

Time Collected: 08:50

By: Mandi Pearson

Date Received: 07/11/2024

Time Received: 08:48

By: Angela Heybroek

Sample Source: Well water

Sampling Point: Tap on house

Sample Type: Raw

GPS No.

Treatment:

Well Permit No. OSS-2024-0746 (W11719)

Comment:

Colilert Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 07/11/2024 |
| E. coli | Absent | | | 07/11/2024 |

Report Date: 07/12/2024

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.