



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Easton Rains

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Jones Chapel Missionary Baptist C
 179 Jones Chapel Rd
 Reidsville, NC 27320

EIN: 566000372X

Delivery: NC Courier

Rockingham County

StarLiMS ID: **ES240813-0038**

Date Collected: 08/12/2024

Time Collected: 10:15 By: Easton Rains

Date Received: 08/13/2024

Time Received: 07:58 By: DeMonta Newborn

Water System ID: 0-79-640

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Kitchen sink

Location Type:

Location Code: KS1

Disinfectant Used:

Free Chlorine:

Total Chlorine: 0.0 mg/L

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/13/2024
E. coli	Absent			08/13/2024

Report Date: 08/15/2024

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.