



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Ben Kirby

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Wayne Trademark

EIN: 566000372X

Delivery: NC Courier

Randolph County

StarLiMS ID: **ES240814-0049**

Date Collected: 08/13/2024

Time Collected: 13:45 By: Ben Kirby

Date Received: 08/14/2024

Time Received: 07:57 By: Kaila Kurtz

Water System ID: 02-76-637

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Breakroom

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine: 0.1 mg/L

Total Chlorine:

Comments: Disinfectant Used: None

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/14/2024
E. coli	Absent			08/14/2024

Report Date: 08/15/2024

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.