



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Union Grove Baptist Church

EIN: 566000372X

Delivery: NC Courier

Guilford County

StarLiMS ID: ES240815-0068	Date Collected: 08/14/2024	Time Collected: 10:13	By: Doug Whitmire
	Date Received: 08/15/2024	Time Received: 08:00	By: Kaila Kurtz
Water System ID: 02-41-418	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Arbor kitchen sink	Location Type:	Location Code: AKS	
Disinfectant Used:	Free Chlorine:	Total Chlorine: 0.0 mg/L	

Comments: Disinfectant Used: None

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/15/2024
E. coli	Absent			08/15/2024

Report Date: 08/16/2024

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.