



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Easton Rains

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Dobbins Creek Vineyard
 4430 Vineyard View Ln
 Hamptonville, NC 27020

EIN: 566000372X

Delivery: NC Courier

Yadkin County

| | | | |
|-----------------------------------|----------------------------|-------------------------------------|---------------------|
| StarLiMS ID: ES240910-0051 | Date Collected: 09/09/2024 | Time Collected: 11:45 | By: Easton Rains |
| | Date Received: 09/10/2024 | Time Received: 08:02 | By: Julie Schiavone |
| Water System ID: 30-99-031 | System Type: NTNC | Water Source: Ground Water | |
| Facility ID: D01 | | Sample Type: Special/Non-Compliance | |
| Sample Location: Outside Spigot | Location Type: | Location Code: GS1 | |
| Disinfectant Used: | Free Chlorine: | Total Chlorine: 0.0 mg/L | |

Comments:

PWS - Colilert Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 09/10/2024 |
| E. coli | Absent | | | 09/10/2024 |

Report Date: 09/11/2024

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.