



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Mandi Pearson

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Ryan Beck
131 Water Dog Way
Hendersonville, NC 28791

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES241022-0082	Date Collected: 10/21/2024	Time Collected: 08:55	By: Mandi Pearson
Barcode ID:	Date Received: 10/22/2024	Time Received: 08:04	By: Julie Schiavone
Sample Source: Hurricane Helene	Sampling Point: Outside spigot		
Sample Type:	GPS No.		
Treatment:	Well Permit No. OSS-2024-1113		

Comment: Days since disinfection: not provided

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			10/22/2024
E. coli	Present			10/22/2024

Report Date: 10/23/2024

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.