



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: CURT CLINE

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

Nicolus Paskiewicz  
207 Wood Dale Dr  
Hendersonville, NC 28791

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES241022-0083** Date Collected: 10/21/2024 Time Collected: 08:31 By: Curt Cline  
Barcode ID: Date Received: 10/22/2024 Time Received: 08:04 By: Julie Schiavone  
Sample Source: Hurricane Helene Sampling Point: Well tap  
Sample Type: GPS No.  
Treatment: Chlorinated Well Permit No.  
Comment: Days since disinfection: 7±  
Flooded well

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			10/22/2024
E. coli	Present			10/22/2024

Report Date: 10/23/2024

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.