



# North Carolina State Laboratory of Public Health

*Environmental Sciences*

**Microbiology**

**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Environmental Health

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

**Robert Ballard**  
2849 Locust Grove Rd  
Hendersonville, NC 28792

**EIN:** 566000307EH

**Delivery:** NC Courier

Henderson County

StarLiMS ID: **ES241024-0058** Date Collected: 10/23/2024 Time Collected: 08:45 By: Robert Ballard  
Date Received: 10/24/2024 Time Received: 07:58 By: Julie Schiavone

Sample Source: Sampling Point: Kitchen Sink

Sample Type: GPS No.

Treatment: Well Permit No.

Comment: Days Since Disinfection: Unknown

## Colilert Profile

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			10/24/2024
E. coli	Present			10/24/2024

**Report Date:** 10/25/2024

**Reported By:** KKURTZ

## Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.