



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Ethan Calloway

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Austin Holloway
200 Whispering Hills Dr
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES241026-0004	Date Collected: 10/25/2024	Time Collected: 08:01	By: Ethan Calloway
Barcode ID: 003194	Date Received: 10/26/2024	Time Received: 10:45	By: Angela Heybroek
Sample Source: Hurricane Helene	Sampling Point: Well head		
Sample Type:	GPS No.		
Treatment:	Well Permit No. OSS-2024-1127		

Comment: Days since disinfection: Unknown.

Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/26/2024
E. coli	Absent			10/26/2024

Report Date: 10/28/2024

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.