



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
 1200 SPARTANBURG HWY - STE 100
 Hendersonville, NC 28792

Charleene Nicely
 555 Lancaster Rd
 Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES241029-0065	Date Collected: 10/28/2024	Time Collected: 08:55	By: Charlene Nicely
Barcode ID: 001551	Date Received: 10/29/2024	Time Received: 08:12	By: Kaila Kurtz
Sample Source: Hurricane Helene	Sampling Point: Kitchen		
Sample Type:	GPS No.		
Treatment: Chlorinated	Well Permit No.		

Comment: Days Since Disinfection 1

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/29/2024
E. coli	Absent			10/29/2024

Report Date: 10/30/2024

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.