



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

Parker Adams  
655 Hoopers Creek Rd  
Fletcher, NC 28732

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES241030-0053** Date Collected: 10/29/2024 Time Collected: 10:00 By: J. Anders  
Barcode ID: Date Received: 10/30/2024 Time Received: 07:57 By: DeMonta Newborn  
Sample Source: Hurricane Helene Sampling Point:  
Sample Type: GPS No.  
Treatment: Well Permit No. 0SS-2024-1129  
Days Since Chlorine Treatment Unknown/Not Given  
Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/30/2024
E. coli	Absent			10/30/2024

Report Date: 10/31/2024

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.