

North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology Certificate of Analysis

4312 District Drive MSC 1918 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com Phone: 919-733-7308 Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - STE 100

Hendersonville, NC 28792

Name of System:

Julia Touchstone 206 Summersweet Ln

Flat Rock, NC 28731

EIN: 566000307EH Delivery: **NC Courier Henderson County**

StarLiMS ID: ES241031-0070

10/30/2024

Time Collected: 08:30

Julia By:

004018 Barcode ID:

Date Collected: Date Received:

10/31/2024

Time Received: 07:54

Kaila Kurtz By:

Sample Source:

Hurricane Helene

kitchen sink Sampling Point:

Sample Type:

GPS No.

Well Permit No. Days Since Chlorine Treatment

Unknown/Not Given

Comment:

Treatment:

Colilert Profile Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			10/31/2024
E. coli	Absent			10/31/2024

11/01/2024 Report Date: Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are Absent, the water is considered safe for drinking purpose. If coliform bacteria are Present, the water is considered unsafe for drinking purpose. Presence of E. coli (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.