



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Lily Keel

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Twin Oaks Garden C
 3985 E Hwy 268
 Pilot Mountain,

EIN: 566000372X

Delivery: NC Courier

Stokes County

StarLiMS ID: ES241113-0052	Date Collected: 11/12/2024	Time Collected: 09:14	By: Lily Keel
	Date Received: 11/13/2024	Time Received: 08:12	By: Julie Schiavone
Water System ID: 02-85-135	System Type: C	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: kitchen sink	Location Type:	Location Code: AC1	
Disinfectant Used:	Free Chlorine: 1.46 mg/L	Total Chlorine:	

Comments: chlorine-hypochlorite solution disinfectant

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			11/13/2024
E. coli	Absent			11/13/2024

Report Date: 11/14/2024

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.