

## North Carolina State Laboratory of Public Health

Environmental Sciences

## **Microbiology Certificate of Analysis**

4312 District Drive MSC 1918 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com Phone: 919-733-7308 Fax: 919-715-8611

**FINAL REPORT** 

Report to: Environmental Health

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - STE 100

Hendersonville, NC 28792

Name of System:

**Faye Wilson** 213 S Rugby Rd

Hendersonville, NC 28791

EIN: 566000307EH Delivery: **NC Courier Henderson County** 

11/12/2024 Time Collected: 07:00 F Wilson StarLiMS ID: ES241113-0075 Date Collected: By:

Julie Schiavone Date Received: 11/13/2024 Time Received: 08:14 By: 003187

Faucet Hurricane Helene Sample Source: Sampling Point:

GPS No.

Sample Type:

Treatment: Well Permit No.

> Days Since Chlorine Treatment Unknown/Not Given

Comment:

Barcode ID:

**Colilert Profile** Method: SM 9223B

| Analyte        | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent      |      |            | 11/13/2024  |
| E. coli        | Absent      |      |            | 11/13/2024  |

11/14/2024 Report Date: Reported By: **KKURTZ** 

## **Explanations of Coliform Analysis:**

If coliform bacteria are Absent, the water is considered safe for drinking purpose. If coliform bacteria are Present, the water is considered unsafe for drinking purpose. Presence of E. coli (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.