



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Ethan Calloway

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

Michelle Spevak  
10 Hutchinson Woods Dr  
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: <b>ES241113-0076</b>	Date Collected: 11/12/2024	Time Collected: 08:30	By: Ethan Calloway
Barcode ID: 001979	Date Received: 11/13/2024	Time Received: 08:14	By: Julie Schiavone
Sample Source: Hurricane Helene	Sampling Point: Well head		
Sample Type:	GPS No.		
Treatment:	Well Permit No. PSS-2024-1177		
	Days Since Chlorine Treatment	Unknown/Not Given	

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			11/13/2024
E. coli	Absent			11/13/2024

Report Date: 11/14/2024

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.