



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

Jana Hale  
1474 Holiday Dr  
Hendersonville, NC 28739

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES241114-0070

Date Collected: 11/13/2024

Time Collected: 07:45

By: Jana Hale

Barcode ID: 003161

Date Received: 11/14/2024

Time Received: 08:13

By: Kaila Kurtz

Sample Source: Hurricane Helene

Sampling Point: Kitchen Faucet

Sample Type:

GPS No.

Treatment: Chorinated

Well Permit No.

Days Since Chlorine Treatment >7 Days

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			11/14/2024
E. coli	Absent			11/14/2024

Report Date: 11/15/2024

Reported By: KKURTZ

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.