



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Bo Harkness
391 Paradise Rd
Saluda, NC 28773

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES241115-0015** Date Collected: 11/14/2024 Time Collected: 08:45 By:
Barcode ID: 001997 Date Received: 11/15/2024 Time Received: 07:56 By: Angela Heybroek
Sample Source: Hurricane Helene Sampling Point: Bath faucet
Sample Type: GPS No.
Treatment: Chorinated Well Permit No.
Days Since Chlorine Treatment <=7 Days

Comment:

Colisure - Quanti-Tray2000 Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|-----------|------------|-------------|
| Total Coliform | 24.3 | MPN/100mL | | 11/15/2024 |
| E. coli | <1 | MPN/100mL | | 11/15/2024 |

Report Date: 11/16/2024

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.