



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Hannah Mitchell

**Name of System:**

**WILMINGTON REGIONAL OFFICE PWSS**  
 127 CARDINAL DRIVE EXTENSION  
 Wilmington, NC

**Hollands Shelter Creek, Inc**

**EIN:** 562033372Q

**Delivery:** NC Courier

**Pender County**

|                                   |                            |                                     |                     |
|-----------------------------------|----------------------------|-------------------------------------|---------------------|
| StarLiMS ID: <b>ES241119-0079</b> | Date Collected: 11/18/2024 | Time Collected: 10:55               | By: Hannah Mitchell |
|                                   | Date Received: 11/19/2024  | Time Received: 08:22                | By: Kaila Kurtz     |
| Water System ID: 04-71-321        | System Type: NTNC          | Water Source: Ground Water          |                     |
| Facility ID: D01                  |                            | Sample Type: Special/Non-Compliance |                     |
| Sample Location: Lot 6            | Location Type:             | Location Code: 006                  |                     |
| Disinfectant Used:                | Free Chlorine:             | Total Chlorine:                     |                     |

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

| Analyte        | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Present     |      |            | 11/19/2024  |
| E. coli        | Absent      |      |            | 11/19/2024  |

**Report Date:** 11/20/2024

**Reported By:** **KKURTZ**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.