



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**AMENDED REPORT**

**Report to:** Environmental Health

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
 1200 SPARTANBURG HWY - STE 100  
 Hendersonville, NC 28792

**Uzi Shemesh**  
 2218 Harden Circle  
 Hendersonville, NC 28739

**EIN:** 566000307EH

**Delivery:** NC Courier

**Henderson County**

StarLiMS ID: <b>ES241123-0001</b>	Date Collected: 11/22/2024	Time Collected: 06:00	By: Uzi Shemesh
Barcode ID: 002495	Date Received: 11/23/2024	Time Received: 10:49	By: Angela Heybroek
Sample Source: Hurricane Helene	Sampling Point: Kitchen		
Sample Type: Treated	GPS No.		
Treatment: Chlorinated	Well Permit No.		
	Days Since Chlorine Treatment	>7 Days	

Comment:

**Colisure Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			11/23/2024
E. coli	Absent			11/23/2024

**Report Date:** 11/25/2024

**Reported By:** **KKURTZ**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.