



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Mandi Pearson

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Larry Boyd
56 Fox Hill Rd
28759

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES250108-0061	Date Collected: 01/07/2025	Time Collected: 09:00	By: Mandi Pearson
Barcode ID:	Date Received: 01/08/2025	Time Received: 07:53	By: Kaila Kurtz
Sample Source: Hurricane Helene	Sampling Point: Kitchen sink		
Sample Type:	GPS No.		
Treatment:	Well Permit No. OSS-2024-1395		
	Days Since Chlorine Treatment	Unknown/Not Given	

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			01/08/2025
E. coli	Absent			01/08/2025

Report Date: 01/09/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.