



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Jeffery Anders

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Chris Kincaid
49 Gerton Hwy
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

Henderson County

| | | | |
|-----------------------------------|-------------------------------|-----------------------|---------------------|
| StarLiMS ID: ES250128-0051 | Date Collected: 01/27/2025 | Time Collected: 10:00 | By: J Anders |
| Barcode ID: | Date Received: 01/28/2025 | Time Received: 08:10 | By: Julie Schiavone |
| Sample Source: Hurricane Helene | Sampling Point: Sink | | |
| Sample Type: | GPS No. | | |
| Treatment: | Well Permit No. OSS-2024-1431 | | |

Comment:

Colilert Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 01/28/2025 |
| E. coli | Absent | | | 01/28/2025 |

Report Date: 01/30/2025

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.