



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Jena A Snelson
1583 Oleta Rd
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES250205-0063** Date Collected: 02/04/2025 Time Collected: 08:00 By: Jena Snelson
Barcode ID: 002455 Date Received: 02/05/2025 Time Received: 08:38 By: Julie Schiavone
Sample Source: Hurricane Helene Sampling Point: kitchen
Sample Type: Treated GPS No.
Treatment: Chlorinated Well Permit No.
Days Since Chlorine Treatment >7 Days

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			02/05/2025
E. coli	Absent			02/05/2025

Report Date: 02/07/2025

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.