



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Hannah Mitchell

Name of System:

WILMINGTON REGIONAL OFFICE PWSS  
127 CARDINAL DRIVE EXTENSION  
Wilmington, NC

Holland's Shelter Creek  
8315 Hwy 53 E  
Burgaw, NC 28425

EIN: 562033372Q

Delivery: NC Courier

Pender County

StarLiMS ID: **ES250225-0034**      Date Collected: 02/24/2025      Time Collected: 11:20      By: Hannah Mitchell  
Date Received: 02/25/2025      Time Received: 07:57      By: Julie Schiavone  
Water System ID: 04-71-321      System Type: NTNC      Water Source: Ground Water  
Facility ID: D01      Sample Type: Special/Non-Compliance  
Sample Location: Entry point      Location Type:      Location Code: E02  
Disinfectant Used:      Free Chlorine:      Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			02/25/2025
E. coli	Absent			02/25/2025

Report Date: 02/27/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.