



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Little Kitchen

EIN: 566000372X

Delivery: NC Courier

Yadkin County

StarLiMS ID: **ES250408-0041** Date Collected: 04/07/2025 Time Collected: 14:33 By: Doug Whitmire
Date Received: 04/08/2025 Time Received: 07:49 By: Kaila Kurtz
Water System ID: 02-99-486 System Type: NTNC Water Source: Ground Water
Facility ID: D01 Sample Type: Special/Non-Compliance
Sample Location: kitchen hand sink Location Type: Location Code: KHS
Disinfectant Used: Free Chlorine: Total Chlorine: 0.0 mg/L

Comments:

PWS - Colisure Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 04/08/2025 |
| E. coli | Absent | | | 04/08/2025 |

Report Date: 04/09/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.