



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Jayla Berry

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
Mooresville, NC 28115

Philadelphia Baptist Church

EIN: 566000037AA

Delivery: NC Courier

Stanly County

StarLiMS ID: ES250416-0039

Date Collected: 04/15/2025

Time Collected: 11:52 By: Jayla Berry

Date Received: 04/16/2025

Time Received: 07:40 By: Kaila Kurtz

Water System ID: 20-84-011

System Type: NTNC

Water Source: Ground Water

Facility ID: W01

Sample Type: Assessment

Sample Location: E01

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine: 0 mg/L

Total Chlorine: 0 mg/L

Comments:

PWS - Colisure Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 04/16/2025 |
| E. coli | Absent | | | 04/16/2025 |

Report Date: 04/17/2025

Reported By: KKURTZ

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.