



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Hannah Mitchell

Name of System:

WILMINGTON REGIONAL OFFICE PWSS  
127 CARDINAL DRIVE EXTENSION  
Wilmington, NC

Hammocks Beach State Park  
Bear Island  
Maintenance Garage  
Swansboro, NC 28584

EIN: 562033372Q

Delivery: NC Courier

Onslow County

StarLiMS ID: **ES250423-0040**      Date Collected: 04/22/2025      Time Collected: 11:00      By: Hannah Mitchell  
Date Received: 04/23/2025      Time Received: 08:02      By: Julie Schiavone  
Water System ID: 04-67-549      System Type: NTNC      Water Source: Ground Water  
Facility ID:      Sample Type: Special/Non-Compliance  
Sample Location: Entry point      Location Type: E01      Location Code:  
Disinfectant Used:      Free Chlorine: 1.07 mg/L      Total Chlorine:

Comments: Disinfectant Used: Hypochlorite solution

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			04/23/2025
E. coli	Absent			04/23/2025

Report Date: 04/24/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.