



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: BRADLEY NEAL ADKINS

Name of System:

WILMINGTON REGIONAL OFFICE PWSS
127 CARDINAL DRIVE EXTENSION
Wilmington, NC

Hammocks Beach State Park
Bear Island
Bath House
Swansboro, NC 28584

EIN: 562033372Q

Delivery: NC Courier

Onslow County

StarLiMS ID: **ES250423-0041** Date Collected: 04/22/2025 Time Collected: 11:25 By: Hannah Mitchell
Date Received: 04/23/2025 Time Received: 08:03 By: Julie Schiavone
Water System ID: 04-67-549 System Type: NTNC Water Source: Ground Water
Facility ID: Sample Type: Special/Non-Compliance
Sample Location: Water fountain Location Type: BH1 Location Code:
Disinfectant Used: Free Chlorine: 0.20 mg/L Total Chlorine:

Comments: Disinfectant Used: Hypochlorite solution

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			04/23/2025
E. coli	Absent			04/23/2025

Report Date: 04/24/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.