



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

AMENDED REPORT

Report to: Mandi Pearson

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

Coston Farms  
823 Apple Valley Rd  
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES250424-0043

Date Collected: 04/23/2025

Time Collected: 08:30

By: Mandi Pearson

Date Received: 04/24/2025

Time Received: 07:47

By: Julie Schiavone

Sample Source: Well water

Sampling Point: Kitchen sink

Sample Type:

GPS No.

Treatment:

Well Permit No. OSS-2025-0186

Comment: Amended report: date recieved changed

Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			04/24/2025
E. coli	Absent			04/24/2025

Report Date: 04/29/2025

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.