



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Welborn Motel

EIN: 566000372X

Delivery: NC Courier

Yadkin County

StarLiMS ID: **ES250429-0048** Date Collected: 04/28/2025 Time Collected: 11:18 By: Doug Whitmire
Date Received: 04/29/2025 Time Received: 07:56 By: Kaila Kurtz
Water System ID: 02-99-456 System Type: NTNC Water Source: Ground Water
Facility ID: Sample Type: Special/Non-Compliance
Sample Location: Kitchen Sink Location Type: Location Code: KS1
Disinfectant Used: Free Chlorine: Total Chlorine: 0.0 mg/L

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			04/29/2025
E. coli	Absent			04/29/2025

Report Date: 04/30/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.