



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Jayla Berry

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
Mooresville, NC 28115

Philadelphia Baptist Church

EIN: 566000037AA

Delivery: NC Courier

Stanly County

StarLiMS ID: ES250603-0053

Date Collected: 06/02/2025

Time Collected: 14:49 By: Jayla Berry

Date Received: 06/03/2025

Time Received: 07:52 By: Kaila Kurtz

Water System ID: 20-83-011

System Type:

Water Source: Ground Water

Facility ID: D01

Sample Type: Special/Non-Compliance

Sample Location: Wellhead

Location Type:

Location Code: F01

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/03/2025
E. coli	Absent			06/03/2025

Report Date: 06/04/2025

Reported By: KKURTZ

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.