



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Jayla Berry

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
Mooresville, NC 28115

Philadelphia Baptist Church

EIN: 566000037AA

Delivery: NC Courier

Stanly County

StarLiMS ID: **ES250603-0054** Date Collected: 06/02/2025 Time Collected: 14:05 By: Jayla Berry
Date Received: 06/03/2025 Time Received: 07:52 By: Kaila Kurtz
Water System ID: 20-84-011 System Type: Water Source: Ground Water
Facility ID: D01 Sample Type: Special/Non-Compliance
Sample Location: Basement Sanctuary | Location Type: Location Code: 003
Disinfectant Used: Free Chlorine: Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/03/2025
E. coli	Absent			06/03/2025

Report Date: 06/04/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.