



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Kyle Spivey

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS  
450 WEST HANES MILL RD STE 300  
Winston Salem, NC 27105

City of Randleman  
402 Pinnacle Dr  
Randleman, NC

EIN: 566000372X

Delivery: NC Courier

Randolph County

StarLiMS ID: **ES250710-0044**      Date Collected: 07/09/2025      Time Collected: 10:25      By: Kyle Spivey  
Date Received: 07/10/2025      Time Received: 07:50      By: Kaila Kurtz  
Water System ID: 02-76-015      System Type: C      Water Source: Surface Water  
Facility ID: D01      Sample Type: Special/Non-Compliance  
Sample Location: 402 Pinnacle      Location Type:      Location Code: 038  
Disinfectant Used:      Free Chlorine:      Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/10/2025
E. coli	Absent			07/10/2025

Report Date: 07/11/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.