



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Pleasant Grove Recreation Cntr

EIN: 566000372X

Delivery: NC Courier

Alamance County

StarLiMS ID: ES250715-0075

Date Collected: 07/14/2025

Time Collected: 12:41 By: Doug Whitmire

Date Received: 07/15/2025

Time Received: 07:51 By: DeMonta Newborn

Water System ID: 02-01-489

System Type: NTNC

Water Source: Ground Water

Facility ID: D01

Sample Type: Special/Non-Compliance

Sample Location: Kitchen sink

Location Type:

Location Code: KS1

Disinfectant Used:

Free Chlorine:

Total Chlorine: 0.0 mg/L

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			07/15/2025
E. coli	Absent			07/15/2025

Report Date: 07/16/2025

Reported By: KKURTZ

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.