



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Brims Grove Baptist Church

EIN: 566000372X

Delivery: NC Courier

Stokes County

StarLiMS ID: **ES250717-0069** Date Collected: 07/16/2025 Time Collected: 15:09 By: Doug Whitmire
Date Received: 07/17/2025 Time Received: 08:01 By: DeMonta Newborn
Water System ID: 02-85-476 System Type: NTNC Water Source: Ground Water
Facility ID: D01 Sample Type: Special/Non-Compliance
Sample Location: Nursery sink Location Type: Location Code: NS1
Disinfectant Used: Free Chlorine: Total Chlorine:
Comments: No disinfectant used

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			07/18/2025
E. coli	Absent			07/18/2025

Report Date: 07/18/2025

Reported By: **DNEWBORN**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.