



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Shawn Fox

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Sellars Mobile Home Park
2273 Willie Pace Rd
Burlington, NC

EIN: 566000372X

Delivery: NC Courier

Alamance County

StarLiMS ID: ES250724-0048

Date Collected: 07/23/2025

Time Collected: 13:42 By: Shawn Fox

Date Received: 07/24/2025

Time Received: 07:42 By: Kaila Kurtz

Water System ID: 02-01-203

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Lot #2

Location Type:

Location Code: 002

Disinfectant Used:

Free Chlorine: 0.47 mg/L

Total Chlorine: N/A mg/L

Comments: Disinfectant Used: Sodium Hypochlorite

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/24/2025
E. coli	Absent			07/24/2025

Report Date: 07/25/2025

Reported By: KKURTZ

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.