



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Quality Mart

EIN: 566000372X

Delivery: NC Courier

Alamance County

StarLiMS ID: ES250805-0051	Date Collected: 08/04/2025	Time Collected: 14:38	By: Doug Whitmire
	Date Received: 08/05/2025	Time Received: 07:46	By: Kaila Kurtz
Water System ID: 02-01-619	System Type: NTNC	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: Laundry tub	Location Type:	Location Code: LT1	
Disinfectant Used:	Free Chlorine:	Total Chlorine: 0.0 mg/L	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/05/2025
E. coli	Absent			08/05/2025

Report Date: 08/06/2025

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.