



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Doug Whitmire

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Oak Ridge Swim Club

EIN: 566000372X

Delivery: NC Courier

Guilford County

StarLiMS ID: ES250909-0054	Date Collected: 09/08/2025	Time Collected: 15:55	By: Doug Whitmire
	Date Received: 09/09/2025	Time Received: 08:06	By: Julie Schiavone
Water System ID: 02-41-491	System Type: NTNC	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: kitchen sink	Location Type:	Location Code: KS1	
Disinfectant Used:	Free Chlorine:	Total Chlorine: 0.0 mg/L	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			09/09/2025
E. coli	Absent			09/09/2025

Report Date: 09/10/2025

Reported By: KKURTZ

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.