



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

AMENDED REPORT

Report to: MOORESVILLE REGIONAL OFFICE PWSS

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS  
610 EAST CENTER AVENUE  
Mooresville, NC 28115

Philadelphia Baptist Church

EIN: 566000037AA

Delivery: NC Courier

Stanly County

StarLiMS ID: ES251001-0064

Date Collected: 09/30/2025

Time Collected: 09:28 By: Blair Murray

Date Received: 10/01/2025

Time Received: 08:03 By: Cille Tutherow

Water System ID: 20-84-011

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: restroom

Location Type:

Location Code: 005

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

| Analyte        | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent      |      |            | 10/01/2025  |
| E. coli        | Absent      |      |            | 10/01/2025  |

Report Date: 10/06/2025

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.