



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

AMENDED REPORT

Report to: MOORESVILLE REGIONAL OFFICE PWSS

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
Mooresville, NC 28115

Philadelphia Baptist Church

EIN: 566000037AA

Delivery: NC Courier

Stanly County

StarLiMS ID: ES251001-0065

Date Collected: 09/30/2025

Time Collected: 09:21 By: Blair Murray

Date Received: 10/01/2025

Time Received: 08:03 By: Cille Tutherow

Water System ID: 20-84-011

System Type: NTNC

Water Source: Ground Water

Facility ID: W01

Sample Type: Special/Non-Compliance

Sample Location:

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments: pump running

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/01/2025
E. coli	Absent			10/01/2025

Report Date: 10/06/2025

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.