



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

Ellie Anders  
577 Duncan Rd  
Flat Rock, NC 28731

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES251104-0110

Date Collected: 11/03/2025

Time Collected: 10:06

By: J Anders

Date Received: 11/04/2025

Time Received: 08:29

By: Angela Heybroek

Sample Source: New Well

Sampling Point: Well

Sample Type: Raw

GPS No.

Treatment:

Well Permit No. OSS-2024-1149

Comment:

Colilert Profile

Method: SM 9223B

| Analyte        | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Present     |      |            | 11/04/2025  |
| E. coli        | Absent      |      |            | 11/04/2025  |

Report Date: 11/05/2025

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.