



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Blair Murray

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
Mooresville, NC 28115

Mt Beulah Bapt Church

EIN: 566000037AA

Delivery: NC Courier

Gaston County

StarLiMS ID: **ES251106-0039** Date Collected: 11/05/2025 Time Collected: 13:26 By: Blair Murray
Date Received: 11/06/2025 Time Received: 07:57 By: Julie Schiavone
Water System ID: 01-36-659 System Type: NTNC Water Source: Ground Water
Facility ID: D01 Sample Type: Special/Non-Compliance
Sample Location: Outside spigot Location Type: Location Code: OSH
Disinfectant Used: Free Chlorine: Total Chlorine:
Comments: Outside yard hydrant

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			11/06/2025
E. coli	Absent			11/06/2025

Report Date: 11/07/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.