



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Blair Murray

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS  
610 EAST CENTER AVENUE  
Mooresville, NC 28115

Mt Beulah Bapt Church

EIN: 566000037AA

Delivery: NC Courier

Gaston County

StarLiMS ID: **ES251106-0041**      Date Collected: 11/05/2025      Time Collected: 15:35      By: Blair Murray  
Date Received: 11/06/2025      Time Received: 07:57      By: Julie Schiavone  
Water System ID: 01-36-659      System Type: NTNC      Water Source: Ground Water  
Facility ID: D01      Sample Type: Special/Non-Compliance  
Sample Location: Men's bathroom      Location Type:      Location Code: MB1  
Disinfectant Used:      Free Chlorine:      Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			11/06/2025
E. coli	Absent			11/06/2025

Report Date: 11/07/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.