



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Kelsey Ellis

Name of System:

WILMINGTON REGIONAL OFFICE PWSS  
127 CARDINAL DRIVE EXTENSION  
Wilmington, NC

Grace Presbyterian Church  
2101 Live Oak St  
Beaufort, NC 28516

EIN: 562033372Q

Delivery: NC Courier

Carteret County

StarLiMS ID: **ES251125-0045**      Date Collected: 11/24/2025      Time Collected: 10:30      By: Kelsey Ellis  
Date Received: 11/25/2025      Time Received: 07:48      By: Kaila Kurtz  
Water System ID: 04-16-508      System Type: NTNC      Water Source: Ground Water  
Facility ID: D01      Sample Type: Special/Non-Compliance  
Sample Location: Well tap      Location Type:      Location Code: W01  
Disinfectant Used:      Free Chlorine:      Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			11/25/2025
E. coli	Absent			11/25/2025

Report Date: 11/26/2025

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.