



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Demonta Newborn

ES - MICRO (INTERNAL)

4312 District Dr.

Raleigh, NC 27607

Name of System:

Community Center

22 Hank Ln

20925

EIN: SLPH MICR

Delivery: NC Courier

StarLiMS ID: N250335-0008

Date Collected: 11/30/2025

Time Collected: 08:01 By: Nancy Washington

Date Received: 12/01/2025

Time Received: 09:09 By: DeMonta Newborn

Water System ID: 2502

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Women's RR

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			12/01/2025
E. coli	Present			12/01/2025

Report Date: 12/01/2025

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.