



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Blair Murray

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
Mooresville, NC 28115

Rhyne Rd RV # 3
Well # 3

EIN: 566000037AA

Delivery: NC Courier

Gaston County

StarLiMS ID: **N250336-0054** Date Collected: 12/01/2025 Time Collected: 14:13 By: Blair Murray
Date Received: 12/02/2025 Time Received: 08:13 By: Julie Schiavone
Water System ID: 20-36-043 System Type: NTNC Water Source: Ground Water
Facility ID: W03 Sample Type: Other
Sample Location: W03 Location Type: Location Code:
Disinfectant Used: Free Chlorine: Total Chlorine:

Comments: Ground Water Rule (GWR) <1 MPN/100mL

PWS - Colilert Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 12/02/2025 |
| E. coli | Absent | | | 12/02/2025 |

Report Date: 12/03/2025

Reported By: CTUTHEROW

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.