



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Blair Murray

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS  
610 EAST CENTER AVENUE  
Mooresville, NC 28115

Rhyne Rd RV # 3  
Lot 35

EIN: 566000037AA

Delivery: NC Courier

Gaston County

StarLiMS ID: <b>N250336-0058</b>	Date Collected: 12/01/2025	Time Collected: 14:49	By: Blair Murray
	Date Received: 12/02/2025	Time Received: 08:14	By: Julie Schiavone
Water System ID: 20-36-043	System Type: NTNC	Water Source: Ground Water	
Facility ID: D01		Sample Type: Special/Non-Compliance	
Sample Location: Lot 35	Location Type:	Location Code: 035	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			12/02/2025
E. coli	Absent			12/02/2025

Report Date: 12/04/2025

Reported By: CTUTHEROW

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.