



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Mandi Pearson

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Lyndsey Mcilwain
170 Mountain Laurel Ln
Fletcher, NC 28732

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: N250351-0085	Date Collected: 12/16/2025	Time Collected: 09:00	By: Mandi Pearson
	Date Received: 12/17/2025	Time Received: 08:37	By: DeMonta Newborn
Sample Desc: New Well	Sampling Point: Well Head		
Sample Source: Raw	GPS No.		
Treatment:	Well Permit No. OSS-2024-0274		

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			12/17/2025
E. coli	Absent			12/17/2025

Report Date: 12/18/2025

Reported By: KKURTZ

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.