



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Environmental Health

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Emily Steel
1688 Bulling Creek Rd
Penrose, NC 28766

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **N260021-0102** Date Collected: 01/20/2026 Time Collected: 08:40 By: Quinton Powell
Date Received: 01/21/2026 Time Received: 08:18 By: Angela Heybroek

Sample Desc: New Well Sampling Point: Well head
Sample Source: Raw GPS No.
Treatment: Well Permit No. OSS-2024-0066

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			01/21/2026
E. coli	Absent			01/21/2026

Report Date: 01/22/2026

Reported By: [DNEWBORN](#)

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.