



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Blair Murray

Name of System:

MOORESVILLE REGIONAL OFFICE PWSS
610 EAST CENTER AVENUE
Mooresville, NC 28115

Southside Baptist Church

EIN: 566000037AA

Delivery:

Gaston County

StarLiMS ID: **N260029-0031** Date Collected: 01/28/2026 Time Collected: 11:48 By: Blair Murray
Date Received: 01/29/2026 Time Received: 08:00 By: Julie Schiavone
Water System ID: 01-36-920 System Type: NTNC Water Source: Ground Water
Facility ID: D01 Sample Type:
Sample Location: Nursery sanctuary Location Type: Location Code: 507
Disinfectant Used: Free Chlorine: Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			01/29/2026
E. coli	Absent			01/29/2026

Report Date: 01/30/2026

Reported By: **KKURTZ**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.